

CERTIFICATE OF ANALYSIS

Batch No: 22-46708
Final Report 5617

Page 1 of 2

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
 51 Clarke Street
 SOUTHBANK
 VIC
 3006
 AUSTRALIA

Laboratory Wangaratta Laboratory
Address 48 Faithfull Street,
 Wangaratta,
 VIC 3677.
Phone 03 5722 2688
Fax 03 5722 4727

Contact: [REDACTED]

PO No: Not Available

Date Sampled: 27-May-2022

Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFAWANG

Date Samples Received: 27-May-2022
Date Issued: 07-Jun-2022

Program Description: CFA VEMTC Program - Wangaratta
Client Ref: CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
EC (Field)	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Redox (Field)	# EA075FD	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	Colilert (2000)	MM514	Wangaratta
Enterolert	MM517	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Name	Title	Name	Title
[REDACTED]	Analyst Wangaratta Sampler	[REDACTED]	Microbiologist

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Batch No: 22-46708
 Report Number: 5617
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWANG
 Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
208990	WA_TA01	Underground Tank		27/05/22 09:00

Analysis - Analyte

	Sample No. Site Code Units	208990 WA_TA01
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.1
EC (Field) - Electrical Conductivity (Field)	uS/cm	240
Field Cl2 - Free Chlorine (Field)	mg/L	4.3
pH (Field) - pH (Field)	Units	8.4
Redox (Field) - Redox Potential (Field)	mV	409.0
Temp (Field) - Temperature (Field)	°C	14.7
Field Cl2 - Total Chlorine (Field)	mg/L	4.9

A blank space indicates no test performed.