

**CERTIFICATE OF ANALYSIS**

**Batch No:** 22-52406  
**Final Report** 15180

Page 1 of 2

**Client:** Senversa Pty Ltd  
**Contact:** [REDACTED]  
**Address:** Ground Floor  
 51 Clarke Street  
 SOUTHBANK  
 VIC  
 3006  
 AUSTRALIA

**Laboratory** Traralgon Laboratory  
**Address** 4/55 Hazelwood Road,  
 Traralgon,  
 VIC 3844  
**Phone** 03 5176 4170  
**Fax** 03 5176 4473

**Contact:** [REDACTED]

**PO No:** Not Available

**Date Sampled:** 29-Jun-2022

**Sampler Name:** [REDACTED]  
**ALS Program Ref:** SEVERSACFAWSALE

**Date Samples Received:** 29-Jun-2022  
**Date Issued:** 05-Jul-2022

**Program Description:** CFA VEMTC Program - West Sale  
**Client Ref:** CFA West Sale APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	Redox (Field)	# EA075FD	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
pH	WA005	Traralgon	Ps aeruginosa	MM528	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

**Signatories**

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients Senior Analyst	[REDACTED]	Team Leader Nutrients

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 22-52406  
 Report Number: 15180  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAWSALE  
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7466452	WS_APWS	Alternative Potable Water Supply	WATER	29/06/22 11:45
7466453	WS_TWT	Treated Water Tank	WATER	29/06/22 12:00

Analysis - Analyte

	Sample No. Site Code Units	7466452 WS_APWS	7466453 WS_TWT
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	4	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0	0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
pH - pH, units	Units	7.4	7.5
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.0	10.1
EC (Field) - Electrical Conductivity (Field)	uS/cm	430	430
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05	0.37
Redox (Field) - Redox Potential (Field)	mV	135.5	142.2
Temp (Field) - Temperature (Field)	°C	9.4	10.0
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05	0.42

A blank space indicates no test performed.