

**CERTIFICATE OF ANALYSIS**

**Batch No:** 22-70908  
*Final Report* 39506

**Page 1 of 2**

*Client:* **Senversa Pty Ltd**

*Laboratory  
Address*

**Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179**

*Contact:* [REDACTED]

*Phone  
Fax*

03 8756 8000  
03 9763 1862

*Address:* [REDACTED]

*Contact:*

[REDACTED]

*PO No:* **Not Available**

*Date Sampled:* **06-Oct-2022**

*Sampler Name:* [REDACTED]

*Date Samples Received:* **07-Oct-2022**

*ALS Program Ref:* **SEVERSACFACENHI**

*Date Issued:* **14-Oct-2022**

*Program Description:* **CFA VEMTC Program - Central Highlands**

*Client Ref:* **CFA Central High. APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

*Signatories*

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
[REDACTED]	<b>Client Manager Analyst Analyst</b>	[REDACTED]	<b>Team Leader Nutrients Analyst</b>

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
 Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
 The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2  
 Batch No: 22-70908  
 Report Number: 39506  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFACENHI  
 Program Description: CFA VEMTC Program - Central Highlands



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7790697	CH_APWS	Alternative Potable Water Supply	WATER	06/10/22 14:00

Analysis - Analyte

	Sample No. Site Code Units	7790697 CH_APWS
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10
Legionella - Total Legionellae	cfu/mL	<10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.7
EC (Field) - Electrical Conductivity (Field)	uS/cm	340
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	8.0
Redox (Field) - Redox Potential (Field)	mV	173.0
Temp (Field) - Temperature (Field)	°C	11.3
Field Cl2 - Total Chlorine (Field)	mg/L	0.09

A blank space indicates no test performed.