

CERTIFICATE OF ANALYSIS

Batch No: 23-28566
Final Report 91678

Page 1 of 2

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
 51 Clarke Street
 SOUTHBANK
 VIC
 3006
 AUSTRALIA

*Laboratory
 Address*

Scoresby Laboratory
 Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

*Phone
 Fax*

03 8756 8000
 03 9763 1862

Contact:

[REDACTED]
 [REDACTED]
 [REDACTED]

PO No:
Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFACENHI

Date Sampled: 10-May-2023
Date Samples Received: 11-May-2023
Date Issued: 19-May-2023

Program Description: CFA VEMTC Program - Central Highlands
Client Ref: Central Highlands APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
 Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-28566
 Report Number: 91678
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFACENHI
 Program Description: CFA VEMTC Program - Central Highlands



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8547568	CH_APWS	Alternative Potable Water Supply	WATER	10/05/23 14:30

Analysis - Analyte	Sample No.	8547568
	Site Code	CH_APWS
	Units	
Temp (Field) - Temperature (Field)	C	10.5
pH (Field) - pH (Field)	Units	7.7
EC (Field) - Electrical Conductivity (Field)	uS/cm	390
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.7
Field Cl2 - Free Chlorine (Field)	mg/L	0.62
Field Cl2 - Total Chlorine (Field)	mg/L	0.73
Redox (Field) - Redox Potential (Field)	mV	144.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.