

CERTIFICATE OF ANALYSIS

Batch No: 23-33007
Final Report 94041

Page 1 of 2

Client: Senversa Pty Ltd

Contact: [REDACTED]

Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

*Laboratory
Address*

Traralgon Laboratory
4/55 Hazelwood Road,
Traralgon,
VIC 3844

*Phone
Fax*

03 5176 4170
03 5176 4473

Contact:

[REDACTED]
[REDACTED]
[REDACTED]

PO No: Not Available

Date Sampled: 23-May-2023

Sampler Name: [REDACTED]

Date Samples Received: 23-May-2023

ALS Program Ref: SEVERSACFAWSALE

Date Issued: 30-May-2023

Program Description: CFA VEMTC Program - West Sale

Client Ref: CFA West Sale APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
Legionella	MM527	Traralgon	pH	WA005	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-33007
 Report Number: 94041
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWSALE
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8625007	WS_APWS	Alternative Potable Water Supply	WATER	23/05/23 13:30

Analysis - Analyte	Sample No.	8625007
	Site Code	WS_APWS
	Units	
Temp (Field) - Temperature (Field)	C	12.0
EC (Field) - Electrical Conductivity (Field)	uS/cm	450
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.4
Field Cl2 - Free Chlorine (Field)	mg/L	0.38
Field Cl2 - Total Chlorine (Field)	mg/L	0.40
Redox (Field) - Redox Potential (Field)	mV	398.8
pH - pH, units	Units	7.7
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.