

CERTIFICATE OF ANALYSIS

Batch No: 23-40866
Final Report 104621

Page 1 of 2

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Laboratory Address
Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
Phone 03 8756 8000
Fax 03 9763 1862
Contact: [REDACTED]
[REDACTED]
[REDACTED]

PO No: Not Available

Date Sampled: 12-Jul-2023

Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFABANG

Date Samples Received: 12-Jul-2023
Date Issued: 21-Jul-2023

Program Description: CFA VEMTC Program - Bangholme
Client Ref: CFA Bangholme APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-40866
 Report Number: 104621
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFABANG
 Program Description: CFA VEMTC Program - Bangholme



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8754777	BA_APWS	Alternative Potable Water Source	WATER	12/07/23 11:30

Analysis - Analyte	Sample No. Site Code Units	8754777 BA_APWS
Temp (Field) - Temperature (Field)	°C	12.1
pH (Field) - pH (Field)	Units	7.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	100
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.3
Field Cl2 - Free Chlorine (Field)	mg/L	1.7
Field Cl2 - Total Chlorine (Field)	mg/L	2.0
Redox (Field) - Redox Potential (Field)	mV	720.8
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.