

## CERTIFICATE OF ANALYSIS

**Batch No:** 23-47248  
*Final Report* 110774

Page 1 of 2

*Client:* [REDACTED]  
*Contact:* [REDACTED]  
*Address:* Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

*Laboratory Address:* Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179  
*Phone:* 03 8756 8000  
*Fax:* 03 9763 1862  
*Contact:* [REDACTED]  
[REDACTED]  
[REDACTED]

*PO No:* Not Available

*Date Sampled:* 10-Aug-2023

*Sampler Name:* [REDACTED]  
*ALS Program Ref:* SEVERSACFABANG

*Date Samples Received:* 10-Aug-2023  
*Date Issued:* 21-Aug-2023

*Program Description:* CFA VEMTC Program - Bangholme  
*Client Ref:* CFA Bangholme APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

*Signatories*

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 23-47248  
 Report Number: 110774  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFABANG  
 Program Description: CFA VEMTC Program - Bangholme



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8869463	BA_APWS	Alternative Potable Water Source	WATER	10/08/23 12:35

Analysis - Analyte	Sample No. Site Code Units	8869463 BA_APWS
Temp (Field) - Temperature (Field)	°C	12.3
pH (Field) - pH (Field)	Units	7.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	110
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.2
Field Cl2 - Free Chlorine (Field)	mg/L	1.5
Field Cl2 - Total Chlorine (Field)	mg/L	1.6
Redox (Field) - Redox Potential (Field)	mV	614.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.