



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: 23-56770
Final Report 121314

Page 1 of 2

Client: [REDACTED]
Contact: [REDACTED]
Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

*Laboratory
Address*

Bendigo Laboratory
15 Wellsford Drive,
East Bendigo,
VIC 3550
03 5441 0700

*Phone
Fax*

Contact:

[REDACTED]
[REDACTED]

PO No: Not Available

Date Sampled: 19-Sep-2023

Sampler Name: [REDACTED]
ALS Program Ref: SEVERSACFAHUNT

Date Samples Received: 19-Sep-2023

Date Issued: 02-Oct-2023

Program Description: CFA VEMTC Program - Huntly
Client Ref: CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Bendigo	DO (Field)	EN67.2	Bendigo
EC (Field)	EN67.2	Bendigo	pH (Field)	EN67.2	Bendigo
Redox (Field)	# EA075FD	Bendigo	Temp (Field)	EN67.2	Bendigo
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 23-56770
 Report Number: 121314
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAHUNT
 Program Description: CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9027944	HU_TA10	Main FTW Source	WATER	19/09/23 11:23

Analysis - Analyte	Sample No. Site Code Units	9027944 HU_TA10
Temp (Field) - Temperature (Field)	°C	12.7
pH (Field) - pH (Field)	Units	7.9
EC (Field) - Electrical Conductivity (Field)	uS/cm	260
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.5
Field Cl2 - Free Chlorine (Field)	mg/L	1.2
Field Cl2 - Total Chlorine (Field)	mg/L	1.4
Redox (Field) - Redox Potential (Field)	mV	632.4
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.