



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

CERTIFICATE OF ANALYSIS

Batch No: **23-62642**
Final Report **127637**

Page 1 of 2

Client: [REDACTED]
Contact: [REDACTED]
Address: [REDACTED]

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone
Fax

03 8756 8000
03 9763 1862

Contact:

[REDACTED]
[REDACTED]

PO No: **7300230690**

Date Sampled: **18-Oct-2023**

Sampler Name: [REDACTED]
ALS Program Ref: **VEOLIA_CFA**

Date Samples Received: **18-Oct-2023**

Date Issued: **27-Oct-2023**

Program Description: **CFA VEMTC**
Client Ref: **CFA Bangholme APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples not collected by ALS and are tested as received.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 23-62642
 Report Number: 127637
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9129046		WTP5 APWS	WATER	18/10/23 10:30

Analysis - Analyte	Sample No. Site Code Units	9129046
pH (Field) - pH (Field)	Units	6.8
Field Cl2 - Free Chlorine (Field)	mg/L	0.57
Field Cl2 - Total Chlorine (Field)	mg/L	0.70
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.