



CERTIFICATE OF ANALYSIS

Batch No: **24-19138**
Final Report **163256**

Page 1 of 2

Client: [REDACTED]
Contact: [REDACTED]
Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory Address: Wangaratta Laboratory
48 Faithfull Street,
Wangaratta,
VIC 3677.
Phone: 03 5722 2688
Fax: 03 5722 4727

Contact: [REDACTED]

PO No: **7300346657**

Date Sampled: **12-Mar-2024**

Sampler Name:

Date Samples Received: **12-Mar-2024**

ALS Program Ref: **VEOLIA_CFA**

Date Issued: **26-Mar-2024**

Program Description: **CFA VEMTC**
Client Ref: **CFA Wangaratta APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Temp (Field)	EN67.2	Wangaratta	BOD5	WP030	Wangaratta
E.coli, Coliforms	MM698	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

Signatories

Name	Title	Name	Title
[REDACTED]	Analyst	[REDACTED]	Laboratory Co-ordinator Wangaratta

Samples not collected by ALS and are tested as received.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-19138
 Report Number: 163256
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9631098	NONE	WTP2 APWS Alternative Potable Water Supply	WATER	12/03/24 12:30

Analysis - Analyte	Sample No. Site Code Units	9631098 NONE
Temp (Field) - Temperature (Field)	°C	28.0
pH (Field) - pH (Field)	Units	6.8
Field Cl2 - Free Chlorine (Field)	mg/L	1.3
Field Cl2 - Total Chlorine (Field)	mg/L	1.4
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.