

CERTIFICATE OF ANALYSIS

Batch No: 22-49785
Final Report 13660

Client: Senversa Pty Ltd
Contact: [REDACTED]
Address: Ground Floor
 51 Clarke Street
 SOUTHBANK
 VIC
 3006
 AUSTRALIA

Page 1 of 2

Laboratory Scoresby Laboratory
Address Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

Phone 03 8756 8000
Fax 03 9763 1862

Contact: [REDACTED]

PO No: Not Available **Date Sampled:** 20-Jun-2022

Sampler Name: [REDACTED] **Date Samples Received:** 20-Jun-2022

ALS Program Ref: SEVERSACFAHUNT **Date Issued:** 28-Jun-2022

Program Description: CFA VEMTC Program - Huntly
Client Ref: CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager Team Leader Microbiology Process Co-ordinator	[REDACTED]	Team Leader Nutrients Analyst

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
 The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 22-49785
 Report Number: 13660
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAHUNT
 Program Description: CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
266608	HU_TA10	Main FTW Source	WATER	20/06/22

Analysis - Analyte

	Sample No. Site Code Units	266608 HU_TA10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	240
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
pH (Field) - pH (Field)	Units	7.4
Redox (Field) - Redox Potential (Field)	mV	202.9
Temp (Field) - Temperature (Field)	°C	10.0
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05

A blank space indicates no test performed.