

## CERTIFICATE OF ANALYSIS

**Batch No:** 22-58453  
*Final Report* 30307

Page 1 of 2

*Client:* Senversa Pty Ltd

*Laboratory Address*

Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179

*Contact:* [REDACTED]

*Phone Fax*

03 8756 8000  
03 9763 1862

*Address:* [REDACTED]

*Contact:*

[REDACTED]

*PO No:* Not Available

*Date Sampled:* 24-Aug-2022

*Sampler Name:* [REDACTED]

*Date Samples Received:* 25-Aug-2022

*ALS Program Ref:* SEVERSACFAPENS

*Date Issued:* 01-Sep-2022

*Program Description:* CFA VEMTC Program - Penshurst

*Client Ref:* CFA Penshurst APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

*The monochloramines component of Field Chlorine is not NATA accredited*

### Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager Analyst	[REDACTED]	Team Leader Nutrients Analyst

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2  
 Batch No: 22-58453  
 Report Number: 30307  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAPENS  
 Program Description: CFA VEMTC Program - Penshurst



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7572924	PE_TA01	Tank	WATER	24/08/22 10:15

Analysis - Analyte

	Sample No. Site Code Units	7572924 PE_TA01
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0 HTEX
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0 HTEX
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.5
EC (Field) - Electrical Conductivity (Field)	uS/cm	1500
Field Cl2 - Free Chlorine (Field)	mg/L	0.64
pH (Field) - pH (Field)	Units	8.2
Redox (Field) - Redox Potential (Field)	mV	313.0
Temp (Field) - Temperature (Field)	°C	10.1
Field Cl2 - Total Chlorine (Field)	mg/L	0.67

HTEX Holding time was not met. Therefore result may be indicative.

*A blank space indicates no test performed.*