

## CERTIFICATE OF ANALYSIS

**Batch No:** 22-65138  
*Final Report* 34255

Page 1 of 2

*Client:* Senversa Pty Ltd

*Laboratory Address*

Scoresby Laboratory  
 Caribbean Business Park,  
 22 Dalmore Drive,  
 Scoresby,  
 VIC 3179

*Contact:* [REDACTED]

*Phone Fax*

03 8756 8000  
 03 9763 1862

*Address:* [REDACTED]

*Contact:*

[REDACTED]

*PO No:* Not Available

*Date Sampled:* 14-Sep-2022

*Sampler Name:* [REDACTED]

*Date Samples Received:* 14-Sep-2022

*ALS Program Ref:* SEVERSACFABANG

*Date Issued:* 21-Sep-2022

*Program Description:* CFA VEMTC Program - Bangholme

*Client Ref:* CFA Bangholme APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

*The monochloramines component of Field Chlorine is not NATA accredited*

*Signatories*

Name	Title	Name	Title
[REDACTED]	Client Manager Analyst	[REDACTED]	Analyst Analyst

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
 The report shall not be reproduced, except in full and results relate only to the items tested.

Page 2 of 2  
 Batch No: 22-65138  
 Report Number: 34255  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFABANG  
 Program Description: CFA VEMTC Program - Bangholme



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7687771	BA_APWS	Alternative Potable Water Source	WATER	14/09/22 10:20

Analysis - Analyte

	Sample No. Site Code Units	7687771 BA_APWS
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.9
EC (Field) - Electrical Conductivity (Field)	uS/cm	82
Field Cl2 - Free Chlorine (Field)	mg/L	0.14
pH (Field) - pH (Field)	Units	7.4
Redox (Field) - Redox Potential (Field)	mV	383.8
Temp (Field) - Temperature (Field)	°C	12.6
Field Cl2 - Total Chlorine (Field)	mg/L	0.22

A blank space indicates no test performed.