

## CERTIFICATE OF ANALYSIS

**Batch No:** 22-73299  
**Final Report** 39873

Page 1 of 2

**Client:** Senversa Pty Ltd

**Contact:** [REDACTED]

**Address:** [REDACTED]

*Laboratory  
Address*

Traralgon Laboratory  
4/55 Hazelwood Road,  
Traralgon,  
VIC 3844

*Phone  
Fax*

03 5176 4170  
03 5176 4473

**Contact:** [REDACTED]

**PO No:** Not Available

**Date Sampled:** 13-Oct-2022

**Sampler Name:** [REDACTED]

**Date Samples Received:** 13-Oct-2022

**ALS Program Ref:** SEVERSACFAWSALE

**Date Issued:** 17-Oct-2022

**Program Description:** CFA VEMTC Program - West Sale

**Client Ref:** CFA West Sale APWS Resamp

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	E.coli, Coliforms	MM698	Traralgon
Enterolert	MM517	Traralgon	pH	WA005	Traralgon
Ps aeruginosa	MM528	Scoresby			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

**Signatories**

Name	Title	Name	Title
[REDACTED]	Analyst	[REDACTED]	Senior Analyst

Samples collected by ALS according to procedure EN/67.  
 Calculated results are based on raw data.

Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 22-73299  
 Report Number: 39873  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAWSALE  
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7830365	WS_APWS	Alternative Potable Water Supply	WATER	13/10/22 11:55

Analysis - Analyte

	Sample No. Site Code Units	7830365 WS_APWS
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	cfu/100mL	0
pH - pH, units	Units	7.4
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.6
EC (Field) - Electrical Conductivity (Field)	uS/cm	430
Field Cl2 - Free Chlorine (Field)	mg/L	<0.05
Redox (Field) - Redox Potential (Field)	mV	121.9
Temp (Field) - Temperature (Field)	°C	13.7
Field Cl2 - Total Chlorine (Field)	mg/L	<0.05

A blank space indicates no test performed.