

CERTIFICATE OF ANALYSIS

Batch No: 22-78790
Final Report 47319

Page 1 of 2

Client: Senversa Pty Ltd

Contact: [REDACTED]

Address: [REDACTED]

Laboratory Traralgon Laboratory
Address 4/55 Hazelwood Road,
 Traralgon,
 VIC 3844
Phone 03 5176 4170
Fax 03 5176 4473

Contact: [REDACTED]

PO No: Not Available

Date Sampled: 10-Nov-2022

Sampler Name: [REDACTED]

Date Samples Received: 10-Nov-2022

ALS Program Ref: SEVERSACFAWSALE

Date Issued: 18-Nov-2022

Program Description: CFA VEMTC Program - West Sale

Client Ref: CFA West Sale APWS Resamp

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	pH (Field)	EN67.2	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	DO	EP025	Traralgon
EC	WA010	Traralgon	Enterolert	MM517	Traralgon
Legionella	MM527	Traralgon	SS at 104+/- 2°C	WA025	Scoresby

DO analysed outside of holding time, therefore is indicative only

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	National Quality Manager	[REDACTED]	Team Leader Microbiology

Samples collected by ALS according to procedure EN/67.
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
 Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 22-78790
 Report Number: 47319
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWSALE
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7934563	WS_APWS	Alternative Potable Water Supply	WATER	10/11/22 09:09

Analysis	Analyte	Sample No. Site Code Units	7934563 WS_APWS
Legionella	Legionella pneumophila	cfu/mL	<10
Legionella	Legionella Species other than L. pneumophila	cfu/mL	<10
Legionella	Total Legionellae	cfu/mL	<10
E.coli, Coliforms	Coliforms	cfu/100mL	0
E.coli, Coliforms	E.coli	cfu/100mL	0
Enterolert	Enterococci	MPN/100mL	0
Field Cl2	Free Chlorine (Field)	mg/L	>8.8
pH (Field)	pH (Field)	Units	8.2
Temp (Field)	Temperature (Field)	C	16.0
Field Cl2	Total Chlorine (Field)	mg/L	>8.8
BOD5	Biochemical Oxygen Demand, 5 Day	mg/L	<2
DO	Dissolved Oxygen, as DO (Meter)	mg/L	8.7
EC	Electrical Conductivity @ 25C	uS/cm	540
SS at 104+/- 2 C	Suspended Solids	mg/L	<2

A blank space indicates no test performed.