

## CERTIFICATE OF ANALYSIS

**Batch No:** 23-23369  
*Final Report* 88836

Page 1 of 2

**Client:** Senversa Pty Ltd  
**Contact:** [REDACTED]  
**Address:** Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

**Laboratory Address:** Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179  
**Phone:** 03 8756 8000  
**Fax:** 03 9763 1862  
**Contact:** [REDACTED]

**PO No:** Not Available

**Date Sampled:** 26-Apr-2023

**Sampler Name:** [REDACTED]  
**ALS Program Ref:** SEVERSACFAPENS

**Date Samples Received:** 27-Apr-2023  
**Date Issued:** 05-May-2023

**Program Description:** CFA VEMTC Program - Penshurst  
**Client Ref:** CFA Penshurst APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	DO (Field)	EN67.2	Scoresby
EC (Field)	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Redox (Field)	# EA075FD	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

**Signatories**

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 23-23369  
 Report Number: 88836  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAPENS  
 Program Description: CFA VEMTC Program - Penshurst



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8458713	PE_TA01	Tank	WATER	26/04/23 09:45

Analysis - Analyte	Sample No. Site Code Units	8458713 PE_TA01
Temp (Field) - Temperature (Field)	°C	17.6
pH (Field) - pH (Field)	Units	8.4
EC (Field) - Electrical Conductivity (Field)	uS/cm	540
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.5
Field Cl2 - Free Chlorine (Field)	mg/L	5.2
Field Cl2 - Total Chlorine (Field)	mg/L	5.2
Redox (Field) - Redox Potential (Field)	mV	669.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.