



CERTIFICATE OF ANALYSIS

Batch No: 17-35168

Final Report 643843

Laboratory

Page 1 of 2

Address

Page

Scoresby Laboratory Caribbean Business Park.

22 Dalmore Drive.

Scoresby,

VIC 3179

03 8756 8000 Phone 03 9763 1862

Contact:

Fax

Client Manager

PO No: Not Available Date Sampled:

Sampler Name:

Client:

Contact:

Address:

PO Box 717

Date Samples Received:

29-Aug-2017 29-Aug-2017

ALS Program Ref:

CFA

Date Issued:

01-Sep-2017

Program Description:

Miscellaneous Analyses

Country Fire Authority

PATTERSON LAKES VIC 3197

Client Ref: **WQMP**

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below

indicates methods not covered by NATA accreditation in the performance of this service .

Analysis Method Method Laboratory Laboratory Analysis Colilert (2000) MM514 Scoresby Ps aeruginosa MM528 Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name Title Name **Deputy Team Leader**

Microbiology

Team Leader Microbiology





Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced

within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

 Page:
 Page 2 of 2

 Batch No:
 17-35168

 Report Number:
 643843

Client: Country Fire Authority

ALS Program Ref: CFA

Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5302747	CFAB02	South MegalitreTank	WATER	29/08/17 12:00
5302748	CFAB03	North MegalitreTank	WATER	29/08/17 11:40

Analysis - Analyte	Sample No. Site Code Units	5302747 CFAB02	5302748 CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.