



CERTIFICATE OF ANALYSIS

Batch No: 18-20051
Final Report 690827

Client: Country Fire Authority

Contact: PO Box 717
 PATTERSON LAKES VIC
 3197

Page Page 1 of 2

Laboratory Scoresby Laboratory
 Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179

Address

Phone 03 8756 8000
Fax 03 9763 1862

PO No: Not Available

Sampler Name:

ALS Program Ref: CFA

Program Description: Miscellaneous Analyses

Client Ref: WQMP - Bangholme

Contact: Client Manager
21-May-2018

Date Sampled: 21-May-2018

Date Samples Received: 25-May-2018

Date Issued:

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service .

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Team Leader Microbiology		Analyst

Samples collected by ALS according to procedure EN/67.
 Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
 Calculated results are based on raw data.
 Legionella species refers to Legionella species other than Legionella pneumophila
 Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5625491	CFAB02	South MegalitreTank	WATER	21/05/18 13:15
5625492	CFAB03	North MegalitreTank	WATER	21/05/18 13:25

Analysis - Analyte	Sample No. Site Code Units	5625491	5625492
		CFAB02	CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	1	0

A blank space indicates no test performed.