

CERTIFICATE OF ANALYSIS

Batch No: 23-12401
Final Report 70688

Page 1 of 2

Client: Senversa Pty Ltd

*Laboratory
Address*

Wangaratta Laboratory
48 Faithfull Street,
Wangaratta,
VIC 3677.

Contact: [REDACTED]

*Phone
Fax*

03 5722 2688
03 5722 4727

Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Contact: [REDACTED]

PO No: Not Available

Date Sampled: 09-Feb-2023

Sampler Name: [REDACTED]

Date Samples Received: 09-Feb-2023

ALS Program Ref: SEVERSACFAWANG

Date Issued: 21-Feb-2023

Program Description: CFA VEMTC Program - Wangaratta

Client Ref: CFA Wangaratta APWS Resam

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
pH (Field)	EN67.2	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	E.coli, Coliforms	MM698	Wangaratta
EC	WA010	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	Redox Potential	# WA075	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-12401
 Report Number: 70688
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWANG
 Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8280937	WA_TA01	Underground Tank		09/02/23 14:15

Analysis - Analyte	Sample No.	8280937
	Site Code	WA_TA01
	Units	
Temp (Field) - Temperature (Field)	°C	25.9
pH (Field) - pH (Field)	Units	8.2
DO (Field) - Dissolved Oxygen (Field)	mg/L	8.0
Field Cl2 - Free Chlorine (Field)	mg/L	0.48
Field Cl2 - Total Chlorine (Field)	mg/L	0.60
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	4
EC - Electrical Conductivity @ 25C	uS/cm	270
Redox Potential - Redox Potential against Calomel reference, (mV)	mV	460
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.