

CERTIFICATE OF ANALYSIS

Batch No: 23-38472
Final Report 100458

Page 1 of 2

Client: Senversa Pty Ltd

Laboratory Address

Bendigo Laboratory
15 Wellsford Drive,
East Bendigo,
VIC 3550

Contact: [REDACTED]

Phone Fax

03 5441 0700

Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Contact: [REDACTED]
[REDACTED]
[REDACTED]

PO No: Not Available

Date Sampled: 21-Jun-2023

Sampler Name: Rod Ellis

Date Samples Received: 21-Jun-2023

ALS Program Ref: SEVERSACFAHUNT

Date Issued: 30-Jun-2023

Program Description: CFA VEMTC Program - Huntly

Client Ref: CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Bendigo	DO (Field)	EN67.2	Bendigo
EC (Field)	EN67.2	Bendigo	pH (Field)	EN67.2	Bendigo
Redox (Field)	# EA075FD	Bendigo	Temp (Field)	EN67.2	Bendigo
BOD5	WP030	Scoresby	E.coli, Coliforms	MM698	Scoresby
Enterococci (mEI)	MM690	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 23-38472
 Report Number: 100458
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAHUNT
 Program Description: CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8714544	HU_TA10	Main FTW Source	WATER	21/06/23 11:59

Analysis - Analyte	Sample No. Site Code Units	8714544 HU_TA10
Temp (Field) - Temperature (Field)	°C	10.6
pH (Field) - pH (Field)	Units	9.1
EC (Field) - Electrical Conductivity (Field)	uS/cm	260
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.9
Field Cl2 - Free Chlorine (Field)	mg/L	2.1
Field Cl2 - Total Chlorine (Field)	mg/L	2.2
Redox (Field) - Redox Potential (Field)	mV	634.3
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterococci (mEI) - Enterococci	cfu/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.