



# CERTIFICATE OF ANALYSIS

Batch No: **23-51976**  
Final Report **114981**

Page 1 of 2

Client: [REDACTED]  
Contact: [REDACTED]  
Address: Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

Laboratory  
Address  
Traralgon Laboratory  
4/55 Hazelwood Road,  
Traralgon,  
VIC 3844  
Phone  
03 5176 4170  
Fax  
03 5176 4473

Contact: [REDACTED]

PO No: **Not Available**

Date Sampled: **30-Aug-2023**

Sampler Name: [REDACTED]  
ALS Program Ref: **SEVERSACFAWSALE**

Date Samples Received: **30-Aug-2023**  
Date Issued: **08-Sep-2023**

Program Description: **CFA VEMTC Program - West Sale**  
Client Ref: **CFA West Sale APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
Legionella	MM527	Scoresby	pH	WA005	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

## Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 23-51976  
 Report Number: 114981  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAWSALE  
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8948315	WS_APWS	Alternative Potable Water Supply	WATER	30/08/23 11:43

Analysis - Analyte	Sample No. Site Code Units	8948315 WS_APWS
Temp (Field) - Temperature (Field)	C	11.9
EC (Field) - Electrical Conductivity (Field)	uS/cm	430
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.5
Field Cl2 - Free Chlorine (Field)	mg/L	0.16
Field Cl2 - Total Chlorine (Field)	mg/L	0.18
Redox (Field) - Redox Potential (Field)	mV	262.4
pH - pH, units	Units	7.7
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.