



# CERTIFICATE OF ANALYSIS

Batch No: **24-14811**  
Final Report **154856**

Page 1 of 2

Client: [REDACTED]  
Contact: [REDACTED]  
Address: Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

Laboratory  
Address  
  
Phone  
Fax  
Contact:

Scoresby Laboratory  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179  
03 8756 8000  
03 9763 1862

PO No: **7300230690**

Date Sampled: **19-Feb-2024**

Sampler Name: [REDACTED]  
ALS Program Ref: **VEOLIA\_CFA**

Date Samples Received: **19-Feb-2024**  
Date Issued: **29-Feb-2024**

Program Description: **CFA VEMTC**  
Client Ref: **CFA VEMTC WTP4 West Sale**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
Colilert (2000)	MM514	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

### Signatories

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients Analyst	[REDACTED]	Analyst Client Manager

Samples not collected by ALS and are tested as received.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-14811  
 Report Number: 154856  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9556675		WTP4 APWS	WATER	19/02/24 11:00

Analysis - Analyte	Sample No. Site Code Units	9556675
Temp (Field) - Temperature (Field)	°C	21.5
pH (Field) - pH (Field)	Units	6.9
Field Cl2 - Free Chlorine (Field)	mg/L	1.5
Field Cl2 - Total Chlorine (Field)	mg/L	1.6
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.