

CERTIFICATE OF ANALYSIS

Batch No:	18-49311	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	721351	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	CFA	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 701 MT WAVERLEY VIC 3149	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
 <i>PO No:</i>	 4500376107 v705	<i>Date Sampled:</i>	30-Oct-2018
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	30-Oct-2018
<i>ALS Program Ref:</i>	CFAGEE	<i>Date Issued:</i>	07-Nov-2018
<i>Program Description:</i>	Analysis for CFA Geelong - Amiad Water Systems		
<i>Client Ref:</i>	WQMP - Penshurst		

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Scoresby
Ps aeruginosa	MM528	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
	Team Leader Nutrients		Analyst
	Chemist		Analyst

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5867042	PE_TA01	Tank	WATER	30/10/18 09:30

Analysis - Analyte	Sample No. Site Code Units	5867042 PE_TA01
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.