

CERTIFICATE OF ANALYSIS

Batch No: 18-48377
Replacement Report 727211
This report replaces Report Number: 724943
Client: Country Fire Authority
Contact:
Address:

Page Page 1 of 2
Laboratory Scoresby Laboratory
Address Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179
Phone 03 8756 8000
Fax 03 9763 1862
Contact: Client Manager

PO No: 4500376037 V703
Sampler Name:
ALS Program Ref: CFA
Program Description: Miscellaneous Analyses
Client Ref: WQMP - Bangholme

Date Sampled: 20-Nov-2018
Date Samples Received: 20-Nov-2018
Date Issued: 05-Dec-2018

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
DO (Field)	EN67.2	Scoresby	EC (Field)	EN67.2	Scoresby
pH (Field)	EN67.2	Scoresby	Redox (Field)	# EA075FD	Scoresby
Temp (Field)	EN67.2	Scoresby	Collert (2000)	MM514	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby

Please note that this is an amended report replacing the one originally sent on 22/11/18. The amendment involves correcting a typographical error made on the Site EC results. The amendments were made by Carmin De Palma on 5/12/2018.

Signatories

Name	Title	Name	Title
	Client Manager		Analyst
	Analyst		

Samples collected by ALS according to procedure EN/67.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5859515	BA_ST01	South Megalitre Tank- Tap on Tank	WATER	20/11/18 08:40
5859516	BA_NT01	North Megalitre Tank- Tap on Tank	WATER	20/11/18 08:15

Analysis - Analyte	Sample No. Site Code Units	5859515 BA_ST01	5859516 BA_NT01
	Temp (Field) - Temperature (Field)	°C	18.1
pH (Field) - pH (Field)	Units	8.6	8.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	830	890
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.2	9.6
Redox (Field) - Redox Potential (Field)	mV	605.2	584.4
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.