

CERTIFICATE OF ANALYSIS

| | | | |
|-----------------------------|--|-------------------------------|--|
| Batch No: | 20-40062 | <i>Page</i> | Page 1 of 2 |
| <i>Final Report</i> | 844223 | <i>Laboratory</i> | Traralgon Laboratory |
| <i>Client:</i> | CFA West Sale Training Ground | <i>Address</i> | 4/55 Hazelwood Road, Traralgon, VIC 3844 |
| <i>Contact:</i> | [REDACTED] | <i>Phone</i> | 03 5176 4170 |
| <i>Address:</i> | [REDACTED] | <i>Fax</i> | 03 5176 4473 |
| | | <i>Contact:</i> | [REDACTED] Client Manager |
| <i>PO No:</i> | 4500425164v1520 | <i>Date Sampled:</i> | 24-Aug-2020 |
| <i>Sampler Name:</i> | [REDACTED] | <i>Date Samples Received:</i> | 24-Aug-2020 |
| <i>ALS Program Ref:</i> | CFATRA | <i>Date Issued:</i> | 01-Sep-2020 |
| <i>Program Description:</i> | Analysis for CFA West Sale Training Ground - Amiad Water Systems | | |
| <i>Client Ref:</i> | WQMP - West Sale | | |

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| Analysis | Method | Laboratory | Analysis | Method | Laboratory |
|------------------|-----------|------------|-----------------|--------|------------|
| Field Cl2 | EN67.2 | Traralgon | DO (Field) | EN67.2 | Traralgon |
| EC (Field) | EN67.2 | Traralgon | pH (Field) | EN67.2 | Traralgon |
| Redox (Field) | # EA075FD | Traralgon | Temp (Field) | EN67.2 | Traralgon |
| BOD5 | WP030 | Scoresby | Colilert (2000) | MM514 | Traralgon |
| Enterolert | MM517 | Traralgon | Ps aeruginosa | MM528 | Traralgon |
| SS at 104+/- 2°C | WA025 | Scoresby | | | |

Signatories

| Name | Title | Name | Title |
|------------|--|------------|----------------------------------|
| [REDACTED] | Client Manager Traralgon Laboratory Manager | [REDACTED] | Team Leader Nutrients Chemist |



Samples collected by ALS according to procedure EN/67.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.
Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|------------------|-------------|-------------------|
| 6675411 | WS_TA02 | Amenities Tap | WATER | 24/08/20 12:10 |

| Analysis - Analyte | Sample No. Site Code Units | 6675411 WS_TA02 |
|--|----------------------------------|--------------------|
| Temp (Field) - Temperature (Field) | C | 11.6 |
| pH (Field) - pH (Field) | Units | 7.1 |
| EC (Field) - Electrical Conductivity (Field) | uS/cm | 430 |
| DO (Field) - Dissolved Oxygen (Field) | mg/L | 10.8 |
| Field Cl2 - Free Chlorine (Field) | mg/L | 0.14 |
| Field Cl2 - Total Chlorine (Field) | mg/L | 0.16 |
| Redox (Field) - Redox Potential (Field) | mV | 183.3 |
| BOD5 - Biochemical Oxygen Demand, 5 Day | mg/L | <2 |
| SS at 104+/- 2 C - Suspended Solids | mg/L | <2 |
| Colilert (2000) - E.coli MPN Colilert | orgs/100mL | 0 |
| Enterolert - Enterococci MPN Enterolert | orgs/100mL | 0 |
| Ps aeruginosa - Pseudomonas aeruginosa | orgs/100mL | 0 |

A blank space indicates no test performed.