

CERTIFICATE OF ANALYSIS

Batch No:	21-22593	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	893078	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	Senversa Pty Ltd	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>	[REDACTED]	<i>Phone</i>	03 5722 2688
<i>Address:</i>	[REDACTED]	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	[REDACTED] Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	29-Apr-2021
<i>Sampler Name:</i>	[REDACTED]	<i>Date Samples Received:</i>	29-Apr-2021
<i>ALS Program Ref:</i>	SEVERSACFAWANG	<i>Date Issued:</i>	05-May-2021
<i>Program Description:</i>	CFA VEMTC Program - Wangaratta		
<i>Client Ref:</i>	CFA Wangaratta - WQMP		

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
EC (Field)	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Redox (Field)	# EA075FD	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	Colilert (2000)	MM514	Wangaratta
Enterococci	MM313	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Name	Title	Name	Title
[REDACTED]	Wangaratta Lab Coordinator Senior Microbiologist	[REDACTED]	Wangaratta Lab Coordinator



Accreditation No. 992
Accredited for compliance with
ISO/IEC 17025 - Testing

This document shall not be reproduced, except in full.

Samples collected by ALS according to procedure EN/67. Samples are tested within holding time unless otherwise stated.

Soil microbiological testing was commenced within 4 days from the day sampled unless otherwise stated.

Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

Page: Page 2 of 2
 Batch No: 21-22593
 Report Number: 893078
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWANG
 Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
6984923	WA_TA01	Underground Tank	WATER	29/04/21 09:05

Analysis - Analyte	Sample No. Site Code Units	6984923 WA_TA01
Temp (Field) - Temperature (Field)	C	17.1
pH (Field) - pH (Field)	Units	8.2
EC (Field) - Electrical Conductivity (Field)	uS/cm	150
DO (Field) - Dissolved Oxygen (Field)	mg/L	7.1
Field Cl2 - Free Chlorine (Field)	mg/L	0.16
Field Cl2 - Total Chlorine (Field)	mg/L	0.72
Redox (Field) - Redox Potential (Field)	mV	141.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterococci - Enterococci	cfu/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.