

CERTIFICATE OF ANALYSIS

Batch No: 22-77079
Final Report 49250

Page 1 of 2

Client: Senversa Pty Ltd

Laboratory Address

Bendigo Laboratory
15 Wellsford Drive,
East Bendigo,
VIC 3550

Contact: [REDACTED]

Phone Fax

03 5441 0700

Address: [REDACTED]

Contact: [REDACTED]

PO No: Not Available

Date Sampled: 15-Nov-2022

Sampler Name: [REDACTED]

Date Samples Received: 15-Nov-2022

ALS Program Ref: SEVERSACFAHUNT

Date Issued: 25-Nov-2022

Program Description: CFA VEMTC Program - Huntly

Client Ref: CFA Huntly APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Bendigo	DO (Field)	EN67.2	Bendigo
EC (Field)	EN67.2	Bendigo	pH (Field)	EN67.2	Bendigo
Redox (Field)	# EA075FD	Bendigo	Temp (Field)	EN67.2	Bendigo
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Scoresby
Enterolert	MM517	Scoresby	Legionella	MM527	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

Signatories

Name	Title	Name	Title
[REDACTED]	Team Leader Nutrients Bendigo Laboratory Manager	[REDACTED]	Analyst Analyst

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Page 2 of 2
 Batch No: 22-77079
 Report Number: 49250
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAHUNT
 Program Description: CFA VEMTC Program - Huntly



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7902164	HU_TA10	Main FTW Source	WATER	15/11/22 13:03

Analysis - Analyte

	Sample No. Site Code Units	7902164 HU_TA10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10
Legionella - Total Legionellae	cfu/mL	<10
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.0
EC (Field) - Electrical Conductivity (Field)	uS/cm	250
Field Cl2 - Free Chlorine (Field)	mg/L	0.23
pH (Field) - pH (Field)	Units	8.2
Redox (Field) - Redox Potential (Field)	mV	360.3
Temp (Field) - Temperature (Field)	°C	16.0
Field Cl2 - Total Chlorine (Field)	mg/L	0.32

A blank space indicates no test performed.