

## CERTIFICATE OF ANALYSIS

**Batch No:** 23-16968  
*Final Report* 74948

Page 1 of 2

**Client:** Senversa Pty Ltd  
**Contact:** [REDACTED]  
**Address:** Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

**Laboratory Address:** Wangaratta Laboratory  
48 Faithfull Street,  
Wangaratta,  
VIC 3677.  
**Phone:** 03 5722 2688  
**Fax:** 03 5722 4727

**Contact:** [REDACTED]  
[REDACTED]  
[REDACTED]

**PO No:** Not Available

**Date Sampled:** 03-Mar-2023

**Sampler Name:** [REDACTED]  
**ALS Program Ref:** SEVERSACFAWANG

**Date Samples Received:** 03-Mar-2023

**Date Issued:** 14-Mar-2023

**Program Description:** CFA VEMTC Program - Wangaratta  
**Client Ref:** CFA Wangaratta Resample

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
Temp (Field)	EN67.2	Wangaratta	BOD5	WP030	Wangaratta
Colilert (2000)	MM514	Wangaratta	EC	WA010	Wangaratta
Enterolert	MM517	Wangaratta	Legionella	MM527	Wangaratta
pH	WA005	Wangaratta	Redox Potential	# WA075	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

### Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 23-16968  
 Report Number: 74948  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAWANG  
 Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8354797	WA_TA01	Underground Tank		03/03/23 09:44

Analysis - Analyte	Sample No. Site Code Units	8354797 WA_TA01
Temp (Field) - Temperature (Field)	C	26.0
DO (Field) - Dissolved Oxygen (Field)	mg/L	8.0
Field Cl2 - Free Chlorine (Field)	mg/L	1.9
Field Cl2 - Total Chlorine (Field)	mg/L	2.1
pH - pH, units	Units	8.3
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	5
EC - Electrical Conductivity @ 25C	uS/cm	300
Redox Potential - Redox Potential against Calomel reference, (mV)	mV	470
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.