

## CERTIFICATE OF ANALYSIS

**Batch No:** 23-26867  
*Final Report* 87177

Page 1 of 2

**Client:** Senversa Pty Ltd

**Contact:** [REDACTED]

**Address:** Ground Floor  
51 Clarke Street  
SOUTHBANK  
VIC  
3006  
AUSTRALIA

*Laboratory  
Address*

Traralgon Laboratory  
4/55 Hazelwood Road,  
Traralgon,  
VIC 3844

*Phone  
Fax*

03 5176 4170  
03 5176 4473

**Contact:**

[REDACTED]  
[REDACTED]  
[REDACTED]

**PO No:** Not Available

**Date Sampled:** 20-Apr-2023

**Sampler Name:** [REDACTED]

**Date Samples Received:** 20-Apr-2023

**ALS Program Ref:** SEVERSACFAWSALE

**Date Issued:** 28-Apr-2023

**Program Description:** CFA VEMTC Program - West Sale

**Client Ref:** CFA West Sale APWS

*The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.*

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Traralgon	DO (Field)	EN67.2	Traralgon
EC (Field)	EN67.2	Traralgon	Redox (Field)	# EA075FD	Traralgon
Temp (Field)	EN67.2	Traralgon	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Traralgon	Enterolert	MM517	Traralgon
Legionella	MM527	Scoresby	pH	WA005	Traralgon
SS at 104+/- 2°C	WA025	Scoresby			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

### Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Page 2 of 2  
 Batch No: 23-26867  
 Report Number: 87177  
 Client: Senversa Pty Ltd  
 ALS Program Ref: SEVERSACFAWSALE  
 Program Description: CFA VEMTC Program - West Sale



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8519091	WS_APWS	Alternative Potable Water Supply	WATER	20/04/23 11:10

Analysis - Analyte	Sample No. Site Code Units	8519091 WS_APWS
Temp (Field) - Temperature (Field)	°C	15.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	450
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.3
Field Cl2 - Free Chlorine (Field)	mg/L	0.55
Field Cl2 - Total Chlorine (Field)	mg/L	0.60
Redox (Field) - Redox Potential (Field)	mV	439.6
pH - pH, units	Units	7.6
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L.	cfu/mL	<10

A blank space indicates no test performed.