



CERTIFICATE OF ANALYSIS

Batch No: **23-52296**
Final Report **114355**

Page 1 of 2

Client: [REDACTED]
Contact: [REDACTED]
Address: Ground Floor
51 Clarke Street
SOUTHBANK
VIC
3006
AUSTRALIA

Laboratory
Address
Wangaratta Laboratory
48 Faithfull Street,
Wangaratta,
VIC 3677.
Phone 03 5722 2688
Fax 03 5722 4727

Contact: [REDACTED]

PO No: **Not Available**

Date Sampled: **29-Aug-2023**

Sampler Name: [REDACTED]
ALS Program Ref: **SEVERSACFAWANG**

Date Samples Received: **29-Oct-2023**
Date Issued: **06-Sep-2023**

Program Description: **CFA VEMTC Program - Wangaratta**
Client Ref: **CFA Wangaratta APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	DO (Field)	EN67.2	Wangaratta
EC (Field)	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Redox (Field)	# EA075FD	Wangaratta	Temp (Field)	EN67.2	Wangaratta
BOD5	WP030	Wangaratta	E.coli, Coliforms	MM698	Wangaratta
Enterolert	MM517	Wangaratta	Legionella	MM527	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

Signatories

Name	Title	Name	Title
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Samples collected by ALS according to procedure EN/67.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 23-52296
 Report Number: 114355
 Client: Senversa Pty Ltd
 ALS Program Ref: SEVERSACFAWANG
 Program Description: CFA VEMTC Program - Wangaratta



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
8954634	WA_TA01	Underground Tank		29/08/23 09:55

Analysis - Analyte	Sample No. Site Code Units	8954634 WA_TA01
Temp (Field) - Temperature (Field)	C	11.9
pH (Field) - pH (Field)	Units	8.2
EC (Field) - Electrical Conductivity (Field)	uS/cm	2900
DO (Field) - Dissolved Oxygen (Field)	mg/L	7.9
Field Cl2 - Free Chlorine (Field)	mg/L	2.1
Field Cl2 - Total Chlorine (Field)	mg/L	2.3
Redox (Field) - Redox Potential (Field)	mV	185.7
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	4
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	1
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.