



# Water Supply

Note: These requirements are contained at Table 4 of Clause 53.02-5 and must not be changes unless agreed in writing by CFA

## Water Supply

Show **XX** litres of effective water supply for fire fighting purposes must be provided which meets the following requirements:

- Is stored in an above ground water tank constructed of concrete or metal.
- All fixed above-ground water pipes and fittings required for firefighting purposes must be made of corrosive resistant metal.
- Include a separate outlet for occupant use.

### **Additional conditions to apply if CFA fittings and access is required (i.e. 10,000 litres)**

- Be located within 60 metres of the outer edge of the approved building.
- The outlet/s of the water tank must be within 4m of the accessway and be unobstructed.
- Be readily identifiable from the building or appropriate identification signage to the satisfaction of CFA must be provided.
- Any pipework and fittings must be a minimum of 65 mm (excluding the CFA coupling).