

CERTIFICATE OF ANALYSIS

Batch No:	17-03641	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	602981	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	CFA	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>		<i>Phone</i>	03 5722 2688
<i>Address:</i>	1 Ely Street WANGARATTA VIC 3677	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	10-Jan-2017
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	10-Jan-2017
<i>ALS Program Ref:</i>	CFAWANG	<i>Date Issued:</i>	16-Jan-2017
<i>Program Description:</i>	Analysis for Amiad Water Systems		
<i>Client Ref:</i>	WQMP		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	EP030WRG	Wangaratta	Colilert (2000)	MM514	Wangaratta
pH	CM060 B	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	EA025WRG	Wangaratta			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Microbiologist		Wangaratta Laboratory Manager



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
 Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5055090		Underground Tank	WATER	10/01/17 11:35
5055093		Main Hydrant	WATER	10/01/17 11:30

Analysis - Analyte	Sample No.	5055090	5055093
	Site Code Units		
pH - pH, units	Units	8.2	7.5
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	2	0

A blank space indicates no test performed.