

**CERTIFICATE OF ANALYSIS**

<b>Batch No:</b>	<b>14-35193</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>452293</b>	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	<b>CFA</b>	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>		<i>Phone</i>	03 5722 2688
<i>Address:</i>	1 Ely Street WANGARATTA VIC 3677	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	Microbiologist
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>13-Aug-2014</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>13-Aug-2014</b>
<i>ALS Program Ref:</i>	<b>CFAWANG</b>	<i>Date Issued:</i>	<b>18-Aug-2014</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Misc Analysis</b>		

The sample(s) referred to in this report were analysed by the following method(s):  
# - NATA accreditation does not cover the performance of this service

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Wangaratta	Colilert (2000)	MM514	Wangaratta
pH	VIC-CM060 B	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	EA025WRG	Wangaratta			

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

**Signatories**

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Analyst</b>		<b>Analyst</b>
	<b>Microbiologist</b>		

Page: Page 2 of 2  
 Batch No: 14-35193  
 Report Number: 452293  
 Client: CFA  
 ALS Program Ref: CFAWANG  
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4002916		Underground Tank	WATER	13/08/14 08:30
4002917		Main Hydrant	WATER	13/08/14 08:45

Analysis - Analyte	Sample No.	4002916	4002917
	Site Code Units		
pH - pH, units	Units	8.4	7.5
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	3	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0