

CERTIFICATE OF ANALYSIS

Batch No:	16-38915	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	582446	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
 <i>PO No:</i>	Not Available	<i>Date Sampled:</i>	26-Sep-2016
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	26-Sep-2016
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	29-Sep-2016
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	WQMP		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
Team Leader Microbiology			

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4890485	CFAB01	Flammable Liquid Tank	WATER	26/09/16 12:20
4890486	CFAB02	South Megalitre Tank	WATER	26/09/16 11:00
4890487	CFAB03	North Megalitre Tank	WATER	26/09/16 11:50

Analysis - Analyte	Sample No.	4890485	4890486	4890487
	Site Code	CFAB01	CFAB02	CFAB03
	Units			
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0

A blank space indicates no test performed.