

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>16-30472</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>568576</b>	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	<b>Country Fire Authority</b>	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>04-Jul-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>04-Jul-2016</b>
<i>ALS Program Ref:</i>	<b>CFA</b>	<i>Date Issued:</i>	<b>11-Jul-2016</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Bangholme Training Campus</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Alg. ScCnt	MB006	Scoresby	BOD5	EP030WRG	Scoresby
Colilert (2000)	MM514	Scoresby	pH	CM060 B	Scoresby
Ps aeruginosa	MM528	Scoresby	SS at 104+/- 2°C	EA025WRG	Scoresby

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.*

*Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.*

### Signatories

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Team Leader Nutrients</b>		<b>Analyst</b>
	<b>Manager Botany</b>		<b>Team Leader Microbiology</b>
	<b>Analyst</b>		

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4824314	CFAB01	Flammable Liquid Tank	WATER	04/07/16 11:50
4824315	CFAB02	South Megalitre Tank	WATER	04/07/16 11:30
4824316	CFAB03	North Megalitre Tank	WATER	04/07/16 11:10

Analysis - Analyte	Sample No. Site Code Units	4824314 CFAB01	4824315 CFAB02	4824316 CFAB03
pH - pH, units	Units	7.8	7.7	7.6
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	4	4	5
SS at 104+/- 2°C - Suspended Solids	mg/L	9	4	6
Alg. ScCnt - Algal analyses		NR IND	NR IND	NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0

IND Reported independently on separate report

A blank space indicates no test performed.