

Learning and Volunteerism
16 Lakeside Drive, East Burwood
Ref: Water Quality 2016-Bangholme Batch-16-16341



Programme Manager
Office of the CEO
Country Fire Authority
8 Lakeside Drive
Burwood East Vic 3151

28 April 2016

To whom it may concern,

Water Monitoring Results: VEMTC Bangholme Campus – Batch 16-16341

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 26 April 2016 exceeded the criterion in the Flammable Liquid Tank. This tank will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely

A handwritten signature in black ink that reads 'John Bell'.

John Bell
VEMTC Lead



John Bell VEMTC Lead
Headquarters – Learning & Volunteerism
16 Lakeside Drive Burwood East Vic 3151
T: 03 9262 8444 E: j.bell@cfa.vic.gov.au

Protecting lives and property



cfa.vic.gov.au

CERTIFICATE OF ANALYSIS

Batch No:	16-16341	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	555738	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Carmin DePalma Client Manager Carmin.DePalma@alsglobal.com
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	26-Apr-2016
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	26-Apr-2016
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	29-Apr-2016
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Bangholme Training Campus		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Deputy Team Leader		Analyst
	Microbiology		



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4715264	CFAB01	Flammable Liquid Tank	WATER	26/04/16 13:10
4715265	CFAB02	South Megalitre Tank	WATER	26/04/16 12:55
4715266	CFAB03	North Megalitre Tank	WATER	26/04/16 12:40

Analysis - Analyte	Sample No. Site Code Units	4715264 CFAB01	4715265 CFAB02	4715266 CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	690	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	30	0	0

A blank space indicates no test performed.