

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>16-37945</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>576341</b>	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	<b>CFA Training Ground - Huntly Campus</b>	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>		<i>Phone</i>	03 5441 0700
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Bendigo Laboratory Manager
 <i>PO No:</i>	 <b>Not Available</b>	 <i>Date Sampled:</i>	 <b>15-Aug-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>15-Aug-2016</b>
<i>ALS Program Ref:</i>	<b>CFABGO</b>	<i>Date Issued:</i>	<b>23-Aug-2016</b>
<i>Program Description:</i>	<b>Analysis for Amiad Water Systems</b>		
<i>Client Ref:</i>	<b>Huntly</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

*Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.*

### Signatories

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Chemist/Analyst</b>		<b>Deputy Team Leader</b>
	<b>Bendigo Laboratory Manager</b>		<b>Microbiology</b>

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4881664		Tank No 8	WATER	15/08/16 10:00
4881665		Tank No 9	WATER	15/08/16 09:55
4881666		Tank No 10	WATER	15/08/16 10:05
4881667		Hydrant	WATER	15/08/16 09:50

Analysis - Analyte	Sample No. Site Code Units	4881664	4881665	4881666	4881667
		BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	9 HTEX	<2 HTEX
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	0

HTEX Holding time was not met. Therefore result may be indicative.

*A blank space indicates no test performed.*