

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>16-19378</b>	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	<b>555312</b>	<i>Laboratory Address</i>	Bendigo Laboratory Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Client:</i>	<b>CFA Training Ground - Huntly Campus</b>	<i>Phone</i>	03 5441 0700
<i>Contact:</i>		<i>Fax</i>	03 5444 5208
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Contact:</i>	Bendigo Laboratory Manager
 <i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>18-Apr-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>18-Apr-2016</b>
<i>ALS Program Ref:</i>	<b>CFABGO</b>	<i>Date Issued:</i>	<b>27-Apr-2016</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Huntly CFA</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	EP030WRG	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

*Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.  
Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM*

*Late Analysis - BOD5[4736331,4736332,4736333,4736334]*

### Signatories

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

<i>Title</i>	<i>Title</i>
<b>Team Leader Microbiology</b>	<b>Process Co-ordinator</b>



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*  
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.  
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.  
 Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4736331		Tank No 8	WATER	18/04/16 10:38
4736332		Tank No 9	WATER	18/04/16 10:33
4736333		Tank No 10	WATER	18/04/16 10:27
4736334		Hydrant	WATER	18/04/16 10:43

Analysis - Analyte	Sample No.	4736331	4736332	4736333	4736334
	Site Code				
	Units				
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2 HTEX	<2 HTEX	3 HTEX	2 HTEX
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	2	0

HTEX Holding time was not met. Therefore result may be indicative.

A blank space indicates no test performed.