

CERTIFICATE OF ANALYSIS

Batch No:	16-52401	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	594025	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	CFA Training Ground - Huntly Campus	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>		<i>Phone</i>	03 5441 0700
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Bendigo Laboratory Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	21-Nov-2016
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	21-Nov-2016
<i>ALS Program Ref:</i>	CFABGO	<i>Date Issued:</i>	28-Nov-2016
<i>Program Description:</i>	Analysis for Amiad Water Systems		
<i>Client Ref:</i>	Analysis		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	EP030WRG	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Bendigo Laboratory Manager		Team Leader Microbiology
	Process Co-ordinator		



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4994829		Tank No 8	WATER	21/11/16 11:50
4994830		Tank No 9	WATER	21/11/16 11:08
4994831		Tank No 10	WATER	21/11/16 09:55
4994832		Hydrant	WATER	21/11/16 11:13

Analysis - Analyte	Sample No. Site Code Units	4994829	4994830	4994831	4994832
		BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	7	3
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	6	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	1	1	0	0

A blank space indicates no test performed.