

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>16-36983</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>574695</b>	<i>Laboratory</i>	Geelong Laboratory
<i>Client:</i>	<b>CFA</b>	<i>Address</i>	49 Carr Street, Geelong, VIC 3220
<i>Contact:</i>		<i>Phone</i>	03 5246 9403
<i>Address:</i>	PO Box 701 MT WAVERLEY VIC 3149	<i>Fax</i>	
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>09-Aug-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>10-Aug-2016</b>
<i>ALS Program Ref:</i>	<b>CFAGEE</b>	<i>Date Issued:</i>	<b>15-Aug-2016</b>
<i>Program Description:</i>	<b>Analysis for CFA Geelong - Amiad Water Systems</b>		
<i>Client Ref:</i>	<b>CFA PENSURST Quarterly</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Geelong	Colilert (200)	MM514	Geelong
Ps aeruginosa	MM528	Geelong	SS at 104+/- 2°C	EA025WRG	Geelong

*Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.*

Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM. Results are approximate and for indicative purposes only.

*Late Analysis - BOD5[4874630]*

**Signatories**

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Senior Chemist</b>		<b>Analyst</b>



Samples not collected by ALS and are tested as received.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*  
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.  
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.  
 Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4874630		Boost Point	WATER	09/08/16 11:30

Analysis - Analyte	Sample No. Site Code Units	4874630
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	2
Colilert (200) - E.coli MPN Colilert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.