

CERTIFICATE OF ANALYSIS

| | | | |
|---------------------|-------------------------------------|-------------------|--|
| Batch No: | 16-22900 | <i>Page</i> | Page 1 of 2 |
| <i>Final Report</i> | 558565 | <i>Laboratory</i> | Wangaratta Laboratory |
| <i>Client:</i> | CFA | <i>Address</i> | 48 Faithfull Street, Wangaratta, VIC 3677. |
| <i>Contact:</i> | | <i>Phone</i> | 03 5722 2688 |
| <i>Address:</i> | 1 Ely Street WANGARATTA VIC 3677 | <i>Fax</i> | 03 5722 4727 |

Contact: Wangaratta Laboratory Manager

| | | | |
|-----------------------------|------------------------|-------------------------------|-------------|
| <i>PO No:</i> | Not Available | <i>Date Sampled:</i> | 10-May-2016 |
| <i>Sampler Name:</i> | | <i>Date Samples Received:</i> | 10-May-2016 |
| <i>ALS Program Ref:</i> | CFAWANG | <i>Date Issued:</i> | 16-May-2016 |
| <i>Program Description:</i> | Miscellaneous Analyses | | |
| <i>Client Ref:</i> | Misc Analysis | | |

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| <i>Analysis</i> | <i>Method</i> | <i>Laboratory</i> | <i>Analysis</i> | <i>Method</i> | <i>Laboratory</i> |
|------------------|---------------|-------------------|-----------------|---------------|-------------------|
| BOD5 | EP030WRG | Wangaratta | Colilert (2000) | MM514 | Wangaratta |
| pH | CM060 B | Wangaratta | Ps aeruginosa | MM528 | Wangaratta |
| SS at 104+/- 2°C | EA025WRG | Wangaratta | | | |

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

| <i>Name</i> | <i>Title</i> | <i>Name</i> | <i>Title</i> |
|-------------|-----------------------|-------------|--------------------------|
| | Analyst | | Analyst |
| | Wangaratta Laboratory | | Team Leader Microbiology |
| | Manager | | |

Page: Page 2 of 2
 Batch No: 16-22900
 Report Number: 558565
 Client: CFA
 ALS Program Ref: CFAWANG
 Program Description: Miscellaneous Analyses



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|------------------|-------------|-------------------|
| 4765193 | | Underground Tank | WATER | 10/05/16 14:25 |
| 4765194 | | Main Hydrant | WATER | 10/05/16 14:15 |

| Analysis - Analyte | Sample No. Site Code Units | 4765193 | 4765194 |
|--|----------------------------------|---------|---------|
| | | | |
| pH - pH, units | Units | 8.4 | 8.3 |
| BOD5 - Biochemical Oxygen Demand, 5 Day | mg/L | <2 | <2 |
| SS at 104+/- 2°C - Suspended Solids | mg/L | <2 | <2 |
| Colilert (2000) - Coliforms MPN Colilert | orgs/100mL | 18 | 0 |
| Colilert (2000) - E.coli MPN Colilert | orgs/100mL | 0 | 0 |
| Ps aeruginosa - Pseudomonas aeruginosa | orgs/100mL | 0 | 0 |

A blank space indicates no test performed.