

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>16-01483</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>537984</b>	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	<b>Country Fire Authority</b>	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>18-Jan-2016</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>18-Jan-2016</b>
<i>ALS Program Ref:</i>	<b>CFA</b>	<i>Date Issued:</i>	<b>21-Jan-2016</b>
<i>Program Description:</i>	<b>Miscellaneous Analyses</b>		
<i>Client Ref:</i>	<b>Bangholme Training Fac.</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Field Information	# FIELD	Scoresby	Colilert (2000)	MM514	Scoresby
Ps aeruginosa	MM528	Scoresby			

*Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.*

### Signatories

*These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11*

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	<b>Client Manager</b>		<b>Analyst</b>
	<b>Analyst</b>		



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*  
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.  
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.  
 Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4601738	CFAB01	Flammable Liquid Tank	WATER	18/01/16 09:15
4601739	CFAB02	South Megalitre Tank	WATER	18/01/16 09:05
4601740	CFAB03	North Megalitre Tank	WATER	18/01/16 09:00
4601741	SW01	CFA DAM	WATER	18/01/16

Analysis - Analyte	Sample No. Site Code Units	4601738 CFAB01	4601739 CFAB02	4601740 CFAB03	4601741 SW01
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0	
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0	
Field Information - Field Information					Dry

Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4601742	SW02	CFA DRAIN 1	WATER	18/01/16
4601743	SW03	CFA DRAIN 2	WATER	18/01/16

Analysis - Analyte	Sample No. Site Code Units	4601742 SW02	4601743 SW03
Field Information - Field Information		Dry	Dry

A blank space indicates no test performed.