



Tuesday, 17 February 2016
Programme Manager
Office of the CEO
Country Fire Authority
8 Lakeside Drive
Burwood East Vic 3151

To whom it may concern,

Water Monitoring Results: VEMTC Bangholme Campus – Batch 16-05292

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 05 February 2016 exceeded the criterion in the Flammable Liquid Tank. This tank will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely

A handwritten signature in black ink that reads 'John Bell'. The signature is stylized and written in cursive.

John Bell
VEMTC Lead



John Bell VEMTC Lead
Headquarters – Learning & Volunteerism
16 Lakeside Drive Burwood East Vic 3151
T: 03 9262 8065 E: j.bell@cfa.vic.gov.au



CERTIFICATE OF ANALYSIS

Batch No: 16-05292
Replacement Report 542712
This report replaces Report Number: 542711
Client: Country Fire Authority
Contact:
Address: PO Box 717
 PATTERSON LAKES VIC 3197

Page 1 of 2
Laboratory Address
 Scoresby Laboratory
 Caribbean Business Park,
 22 Dalmore Drive,
 Scoresby,
 VIC 3179
Phone 03 8756 8000
Fax 03 9763 1862
Contact: Client Manager

PO No: Not Available
Sampler Name:
ALS Program Ref: CFA
Program Description: Miscellaneous Analyses
Client Ref: Bangholme Training Fac.

Date Sampled: 05-Feb-2016
Date Samples Received: 05-Feb-2016
Date Issued: 17-Feb-2016

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Analyst		Deputy Team Leader Microbiology

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4630440	CFAB01	Flammable Liquid Tank	WATER	05/02/16 10:45
4630441	CFAB02	South Megalitre Tank	WATER	05/02/16 10:20
4630443	CFAB03	North Megalitre Tank	WATER	05/02/16 09:55

Analysis - Analyte	Sample No. Site Code Units	4630440	4630441	4630443
		CFAB01	CFAB02	CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	430	0	0

A blank space indicates no test performed.