

CERTIFICATE OF ANALYSIS

Batch No:	17-18636	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	620392	<i>Laboratory</i>	Wangaratta Laboratory
<i>Client:</i>	CFA	<i>Address</i>	48 Faithfull Street, Wangaratta, VIC 3677.
<i>Contact:</i>		<i>Phone</i>	03 5722 2688
<i>Address:</i>	1 Ely Street WANGARATTA VIC 3677	<i>Fax</i>	03 5722 4727
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	12-Apr-2017
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	12-Apr-2017
<i>ALS Program Ref:</i>	CFAWANG	<i>Date Issued:</i>	18-Apr-2017
<i>Program Description:</i>	Analysis for Amiad Water Systems		
<i>Client Ref:</i>	WQMP		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Wangaratta	Colilert (2000)	MM514	Wangaratta
pH	CM060 B	Wangaratta	Ps aeruginosa	MM528	Wangaratta
SS at 104+/- 2°C	WA025	Wangaratta			

*Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.
Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.*

Samples received 12:40 12/04/2017

Samples tested 15:00 12/04/2017

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Deputy Team Leader Microbiology		Wangaratta Laboratory Manager

Samples collected by ALS according to procedure EN/67.
Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.
MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5167867		Underground Tank	WATER	12/04/17 11:40
5167868		Main Hydrant	WATER	12/04/17 11:35

Analysis - Analyte	Sample No. Site Code Units	5167867	5167868
	pH - pH, units	Units	8.8
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	2	0

A blank space indicates no test performed.