

CERTIFICATE OF ANALYSIS

Batch No:	17-04919	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	605763	<i>Laboratory</i>	Traralgon Laboratory
<i>Client:</i>	CFA West Sale TrainingGround	<i>Address</i>	4/55 Hazelwood Road, Traralgon, VIC 3844
<i>Contact:</i>	PO Box 1212	<i>Phone</i>	03 5176 4170
<i>Address:</i>	SALE VIC 3850	<i>Fax</i>	03 5176 4473

Contact: Client Manager

Not Available

<i>PO No:</i>		<i>Date Sampled:</i>	18-Jan-2017
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	18-Jan-2017
<i>ALS Program Ref:</i>	CFATRA	<i>Date Issued:</i>	31-Jan-2017

Program Description: **Analysis for CFA West Sale Training Ground - Amiad Water Systems**

Client Ref: **WQMP**

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Traralgon
Enterococci	MM572	Traralgon	pH	CM060 B	Traralgon
Ps aeruginosa	MM528	Traralgon	SS at 104+/- 2°C	WA025	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Team Leader Nutrients		Analyst
	Traralgon Laboratory Manager		



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. *Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.*

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Page: Page 2 of 2
 Batch No: 17-04919
 Report Number: 605763
 Client: CFA West Sale Training Ground
 ALS Program Ref: CFATRA
 Program Description: Analysis for CFA West Sale Training Ground - Amiad Water Systems



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5063092		Water Supply to Fire Service	WATER	18/01/17 13:00
5063093		Water Supply to Amenities	WATER	18/01/17 13:10

Analysis - Analyte	Sample No.	5063092	5063093
	Site Code Units		
pH - pH, units	Units	8.2	7.9
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	6	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	0
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterococci - Enterococci	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.