



Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Table with 4 columns: Field Name, Value, Page, and Laboratory/Contact Info. Includes fields like Batch No, Client, Address, Date Sampled, etc.

The sample(s) referred to in this report were analysed by the following method(s):
- NATA accreditation does not cover the performance of this service

Table with 6 columns: Analysis, Method, Laboratory, Analysis, Method, Laboratory. Row 1: Colilert (2000), MM514, Scoresby, Ps aeruginosa, MM528, Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Table with 4 columns: Name, Title, Name, Title. Row 1: Deputy Team Leader Microbiology, Analyst

Samples not collected by ALS and are tested as received.
Soil results expressed in mg/kg dry weight unless specified otherwise.
Microbiological testing was commenced within 24 hours of sampling unless otherwise stated.
VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
Calculated results are based on raw data.

Page: Page 2 of 2
 Batch No: 15-15871
 Report Number: 489116
 Client: CFA
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



| Sample No | Site Code | Site Description | Sample Type | Sampled Date/Time |
|-----------|-----------|-----------------------|-------------|-------------------|
| 4278406 | | Flammable Liquid Tank | WATER | 27/03/15 |
| 4278407 | | South Megalitre Tank | WATER | 27/03/15 |
| 4278408 | | North Megalitre Tank | WATER | 27/03/15 |

| Analysis - Analyte | Sample No. | 4278406 | 4278407 | 4278408 |
|--|--------------------|---------|---------|---------|
| | Site Code Units | | | |
| Colilert (2000) - E.coli MPN Colilert | orgs/100mL | 0 | 0 | 0 |
| Ps aeruginosa - Pseudomonas aeruginosa | orgs/100mL | 0 | 0 | 0 |