

CERTIFICATE OF ANALYSIS

Batch No:	15-49386	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	526050	<i>Laboratory</i>	Traralgon Laboratory
<i>Client:</i>	CFA West Sale Training Ground	<i>Address</i>	4/55 Hazelwood Road, Traralgon, VIC 3844
<i>Contact:</i>		<i>Phone</i>	03 5176 4170
<i>Address:</i>	PO Box 1212 SALE VIC 3850	<i>Fax</i>	03 5176 4473
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	09-Nov-2015
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	09-Nov-2015
<i>ALS Program Ref:</i>	CFATRA	<i>Date Issued:</i>	17-Nov-2015
<i>Program Description:</i>	Miscellaneous Analyses for CFA West Sale Training Ground		
<i>Client Ref:</i>	Analysis		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	EP030WRG	Scoresby	Colilert (2000)	MM514	Traralgon
Enterococci	MM572	Traralgon	pH	VIC-CM060 B	Traralgon
Ps aeruginosa	MM528	Traralgon	SS at 104+/- 2°C	EA025WRG	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Team Leader Nutrients Traralgon Laboratory Manager		Analyst

Page: Page 2 of 2
 Batch No: 15-49386
 Report Number: 526050
 Client: CFA West Sale Training Ground
 ALS Program Ref: CFATRA
 Program Description: Miscellaneous Analyses for CFA West Sale Training Ground



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4538344		Tank Supply to Fire Service	WATER	09/11/15 09:52
4538345		Tank Supply to Amenities	WATER	09/11/15 09:58

Analysis - Analyte	Sample No.	4538344	4538345
	Site Code Units		
pH - pH, units	Units	7.7	8.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - Coliforms MPN Colilert	orgs/100mL	0	39
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterococci - Enterococci	orgs/100mL	2	<2
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	<2	4