



Wednesday, 28 October 2015
Executive Director
Office of the CEO
Country Fire Authority
8 Lakeside Drive
Burwood East Vic 3151

To whom it may concern

Water Monitoring Results: Longerenong Training Campus – Batch 15-47314

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 21 October 2015 exceeded the criterion in the Primary supply. This Primary supply will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely



John Bell
Lead VEMTC Operations



John Bell Lead VEMTC Operations
CFA Learning & Volunteerism
16 Lakeside Drive Burwood East Vic 3151
PO Box 701, Mt Waverley VIC 3149

CERTIFICATE OF ANALYSIS

Batch No:	15-47314	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	522937	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	CFA Longerenong Campus West Road Longerenong DOOEN VIC 3401	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	21-Oct-2015
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	22-Oct-2015
<i>ALS Program Ref:</i>	CFALONG	<i>Date Issued:</i>	27-Oct-2015
<i>Program Description:</i>	Miscellaneous Analysis for CFA Longerenong		
<i>Client Ref:</i>	CFA Longerenong		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
BOD5	EP030WRG	Scoresby	Colilert (2000)	MM514	Scoresby
pH	VIC-CM060 B	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	EA025WRG	Scoresby	Turbidity	VIC-CM013	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Team Leader Nutrients		Analyst
	Team Leader Microbiology		Analyst

Page: Page 2 of 2
 Batch No: 15-47314
 Report Number: 522937
 Client: Country Fire Authority
 ALS Program Ref: CFALONG
 Program Description: Miscellaneous Analysis for CFA Longerenong



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4521058		Primary Supply	WATER	21/10/15 15:45
4521059		Secondary Supply	WATER	21/10/15 15:45

Analysis - Analyte	Sample No.	4521058	4521059
	Site Code Units		
pH - pH, units	Units	7.2	7.2
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	2	2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	2
Turbidity - Turbidity, NTU	NTU	2.9	3.8
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	29	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0