

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>15-48994</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>524462</b>	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	<b>Country Fire Authority</b>	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	CFA Longerenong Campus West Road Longerenong DOOEN VIC 3401	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
<i>PO No:</i>	<b>Not Available</b>	<i>Date Sampled:</i>	<b>04-Nov-2015</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>05-Nov-2015</b>
<i>ALS Program Ref:</i>	<b>CFALONG</b>	<i>Date Issued:</i>	<b>06-Nov-2015</b>
<i>Program Description:</i>	<b>Miscellaneous Analysis for CFA Longerenong</b>		
<i>Client Ref:</i>	<b>CFA Longerenong</b>		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Colilert (2000)	MM514	Scoresby			

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

### Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
-	Analyst	-	-

Page: Page 2 of 2  
 Batch No: 15-48994  
 Report Number: 524462  
 Client: Country Fire Authority  
 ALS Program Ref: CFALONG  
 Program Description: Miscellaneous Analysis for CFA Longerenong



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4536334		Primary Supply 1	WATER	04/11/15 11:30
4536335		Primary Supply 2	WATER	04/11/15 11:30

Analysis - Analyte	Sample No.	4536334	4536335
	Site Code Units		
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	10	24