



Monday, 7 September 2015

Programme Manager
Office of the CEO
Country Fire Authority
8 Lakeside Drive
Burwood East Vic 3151

TO WHOM IT MAY CONCERN

Water Monitoring Results: Bangholme Campus – Batch 15-39274

I refer to the attached water test results received from the ALS Group, who undertook the tests in accordance with the water monitoring program set out in CFA's Water Management Plans. ALS Group is an independent laboratory certified by the National Association of Testing Authorities (NATA).

The attached test results indicate that the water sample collected on 3rd September exceeded the criterion in the Flammable Liquid tank. This tank will not be used for training until corrective action is taken and a successful test result is achieved.

Yours sincerely

A handwritten signature in black ink that reads 'John Bell'. The signature is fluid and cursive, with the first letters of 'John' and 'Bell' being significantly larger and more prominent.

John Bell
Lead VEMTC Operations



John Bell Lead VEMTC Operations
Headquarters – Learning & Volunteerism
16 Lakeside Drive Burwood East Vic 3151
T: 03 9262 8065 E: j.bell@cfa.vic.gov.au





Environmental Division (Water Resources Group)



CERTIFICATE OF ANALYSIS

Batch No:	15-39274	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	514942	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	CFA	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	03-Sep-2015
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	31-Aug-2015
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	07-Sep-2015
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	Bangholme Training Tanks		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>	<i>Analysis</i>	<i>Method</i>	<i>Laboratory</i>
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

<i>Name</i>	<i>Title</i>	<i>Name</i>	<i>Title</i>
	Analyst		Analyst



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Microbiological testing was commenced on the day of receipt and within 24 hours of sampling unless otherwise stated.

VIC-MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

VIC-MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Environmental

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

Page: Page 2 of 2
 Batch No: 15-39274
 Report Number: 517717
 Client: Country Fire Authority
 ALS Program Ref: CFA
 Program Description: Miscellaneous Analyses



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
4458584	CFAB01	Flammable Liquid Tank	WATER	03/09/15 11:44
4458585	CFAB02	South Megalitre Tank	WATER	03/09/15 11:35
4458586	CFAB03	North Megalitre Tank	WATER	03/09/15 11:25

Analysis - Analyte	Sample No.	4458584	4458585	4458586
	Site Code	CFAB01	CFAB02	CFAB03
	Units			
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	7	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	57	0	0